

§ 111.01-1

- 111.97-5 Electric and hydraulic power supply.
- 111.97-7 Distribution.
- 111.97-9 Overcurrent protection.

Subpart 111.99—Fire Door Holding and Release Systems

- 111.99-1 Applicability.
- 111.99-3 Definitions.
- 111.99-5 General.

Subpart 111.101—Submersible Motor-Driven Bilge Pumps

- 111.101-1 Applicability.
- 111.101-3 General requirements.

Subpart 111.103—Remote Stopping Systems

- 111.103-1 Power ventilation systems except machinery space ventilation systems.
- 111.103-3 Machinery space ventilation.
- 111.103-7 Ventilation stop stations.
- 111.103-9 Machinery stop stations.

Subpart 111.105—Hazardous Locations

- 111.105-1 Applicability.
- 111.105-3 General requirements.
- 111.105-5 System integrity.
- 111.105-7 Approved equipment.
- 111.105-9 Explosionproof and flameproof equipment.
- 111.105-11 Intrinsically safe systems.
- 111.105-15 Additional methods of protection.
- 111.105-17 Wiring methods for hazardous locations.
- 111.105-19 Switches.
- 111.105-21 Ventilation.
- 111.105-27 Belt drives.
- 111.105-29 Combustible liquid cargo carriers.
- 111.105-31 Flammable or combustible cargo with a flashpoint below 60 degrees C (140 degrees F), liquid sulphur carriers and inorganic acid carriers.
- 111.105-32 Bulk liquefied flammable gas and ammonia carriers.
- 111.105-33 Mobile offshore drilling units.
- 111.105-35 Vessels carrying coal.
- 111.105-37 Flammable anesthetics.
- 111.105-39 Additional requirements for vessels carrying vehicles with fuel in their tanks.
- 111.105-40 Additional requirements for RO/RO vessels.
- 111.105-41 Battery rooms.
- 111.105-43 Paint stowage or mixing spaces.
- 111.105-45 Vessels carrying agricultural products.

Subpart 111.107—Industrial Systems

- 111.107-1 Industrial systems.

AUTHORITY: 46 U.S.C. 3306, 3703; 49 CFR 1.46.

46 CFR Ch. I (10-1-98 Edition)

SOURCE: CGD 74-125A, 47 FR 15236, Apr. 8, 1982, unless otherwise noted.

Subpart 111.01—General

§ 111.01-1 General.

(a) Electric installations on vessels must ensure:

(1) Maintenance of services necessary for safety under normal and emergency conditions.

(2) Protection of passengers, crew, other persons, and the vessel from electrical hazards.

(3) Maintenance of system integrity through compliance with the applicable system requirements (IEEE, NEC, IEC, etc.) to which plan review has been approved.

(b) Combustible material should be avoided in the construction of electrical equipment.

[CGD 74-125A, 47 FR 15236, Apr. 8, 1982, as amended by CGD 94-108, 61 FR 28275, June 4, 1996; 62 FR 23907, May 1, 1997]

§ 111.01-3 Placement of equipment.

(a) Electric equipment must be arranged, as far as practicable, to prevent mechanical damage to the equipment from the accumulation of dust, oil vapors, steam, or dripping liquids.

(b) Apparatus that may arc must be ventilated or be in ventilated compartments in which flammable gases, acid fumes, and oil vapors cannot accumulate. Skylights and ventilators must be arranged to prevent flooding of the apparatus.

§ 111.01-5 Protection from bilge water.

Each of the following in or around the bilge area must be arranged or constructed so that it cannot be damaged by bilge water:

- (a) Generators.
- (b) Motors.
- (c) Electric coupling.
- (d) Electric cable.

[CGD 94-108, 61 FR 28275, June 4, 1996]

§ 111.01-7 Accessibility and spacing.

(a) The design and arrangement of electric apparatus must afford accessibility to each part as needed to facilitate proper inspection, adjustment, maintenance, or replacement.

(b) Within an enclosure, the spacing between energized components (or between an energized component and ground) must be to the appropriate industry standard for the voltage and current utilized in the circuit. Additionally, spacing within any enclosure must be sufficient to facilitate servicing.

[CGD 94-108, 61 FR 28275, June 4, 1996]

§ 111.01-9 Degrees of protection.

(a) Interior electrical equipment exposed to dripping liquids or falling solid particles must be manufactured to at least NEMA 250 Type 2 or IEC IP 22 degree of protection as appropriate for the service intended.

(b) Electrical equipment in locations requiring exceptional degrees of protection as defined in § 110.15-1 of this chapter must be enclosed to meet at least the minimum degrees of protection in ABS Rules for Building and Classing Steel Vessels, table 4/5B.1, or appropriate NEMA 250 Type for the service intended. Each enclosure must be designed in such a way that the total rated temperature of the equipment inside the enclosure is not exceeded.

(c) Central control consoles and similar control enclosures must be manufactured to at least NEMA 250 Type 2 or IEC IP 22 degree of protection regardless of location.

(d) Equipment for interior locations not requiring exceptional degrees of protection must be manufactured to at least NEMA 250 Type 1 with dripshield or IEC IP 11.

NOTE TO § 111.01-9: The degrees of protection specified in this section are described in NEMA Standards Publication No. 250 and IEC IP Code 529 and designated in ABS Rules for Building and Classing Steel Vessels, table 4/5B.1.

[CGD 94-108, 61 FR 28275, June 4, 1996, as amended at 62 FR 23907, May 1, 1997]

§ 111.01-11 Corrosion-resistant parts.

Each enclosure and part of electric equipment that can be damaged by corrosion must be made of corrosion-resistant materials or of materials having a corrosion resistant finish.

§ 111.01-13 Limitations on porcelain use.

Porcelain must not be used for lamp sockets, switches, receptacles, fuse blocks, or other electric equipment where the item is solidly mounted by machine screws or their equivalent, unless the porcelain piece is resiliently mounted.

§ 111.01-15 Temperature ratings.

(a) In this subchapter, an ambient temperature of 40°C is assumed except as otherwise stated.

(b) A 50°C ambient temperature is assumed for all rotating electrical machinery in boiler rooms, engine rooms, auxiliary machinery rooms, and weather decks, unless it can be shown that a 45°C ambient temperature will not be exceeded in these spaces.

(c) A 45°C ambient temperature is assumed for cable and all other non-rotating electrical equipment in boiler rooms, in engine rooms, in auxiliary machinery rooms, and on weather decks. For installations using UL 489 SA marine type circuit breakers the ambient temperature for that component is assumed to be 40°C. For installations using Navy type circuit breakers the ambient temperature for that component is assumed to be 50°C.

(d) Unless otherwise indicated in this subchapter, a 55°C ambient temperature is assumed for all control and instrumentation equipment.

(e) If electrical equipment is utilized in a space in which the equipment's rated ambient temperature is below the assumed ambient temperature of the space, its load must be derated. The assumed ambient temperature of the space plus the equipment's actual temperature rise at its derated load must not exceed the equipment's total rated temperature (equipment's rated ambient temperature plus its rated temperature rise).

[CGD 94-108, 61 FR 28276, June 4, 1996, as amended at 62 FR 23907, May 1, 1997]

§ 111.01-17 Voltage and frequency variations.

Unless otherwise stated, electrical equipment must function at variations of at least ± 5 percent of rated frequency and +6 percent to -10 percent